

Raport de inspectie Nr.:
PBZ-0078372RO din: 14-OCT-2024
ora: 17:57

Produsul: Pacura usoara
 Fabricat de OMV Petrom S.A. - membru OMV Grup in rafinaria Petrobrazi
Lotul: 2602PE0655241013 Rez T91
Comanda: 12345 din: 13.10.2024
Proba din: 13.10.2024 05:08 prelevata conform: EN ISO 3170
Este conforma cu: R33 Ed. 2 / Aug. 2020

Caracteristica	UM	Valoare prevazuta	Valoare determinata	Metoda
Densitatea la 15 gr C	kg/m ³	970.00 - 990.00	976.20	ASTM D7042
Continut de sulf total	% m/m	<=1	0.712	ASTM D2622
Punct de curgere	°C	<=15	0	ASTM D97
Continut de cenusa	% m/m	<=0.1	0.055	SR EN ISO 6245
Punct de inflamabilitate	°C	>=66	106.5	SR EN ISO 2719
Carbon rezidual	% m/m	<=10	7.8	SR ISO 10370
Continut de asfaltene	% m/m	<=5	1.1	ASTM D6560
Continut de apa	% m/m	<=0.5	0.15	ASTM D95
Apa si sediment	% m/m	<=1		ASTM
Vascozitatea la 50 oC	cSt	50 - 180	79.24	D95+ASTMD473 ASTM D7042
Nichel	mg/kg	<=50	27.7	IP 501
Vanadiu	mg/kg	<=70	6.4	IP 501
Sodiu	mg/kg	<=80	10.3	IP 501
Putere calorifica inferioara	kcal/kg	>=9500	9640	ASTM D240

Informatii aditionale pentru intocmire factura

Dens la 15 gr C corectata in aer (kg/m ³)	975.10
Densitatea la temperatura probei (kg/m ³)	953.10
Temperatura probei (grade C)	50.00

Sef Control Calitate / responsabil delegat

Alina Manea

 Digitally signed by
 ALINA-MARIA MANEA
 Date: 2024.10.14 18:06:40 +03'00'

 Rafinaria Petrobrazi
 Str. Trandafirilor 65, 107080, Brazi, Prahova, Romania
 Quality Control Dept. - Gabriela Ion, gabriela.ion@petrom.com, +40 (728) 988 994

Se certifica faptul ca proba a fost analizata cu metodele specificate si ca lotul reprezentat de proba este conform cu specificatiile mentionate mai sus.